

Building ID	Sample Date	Fixture Type	Sample Type	Concentration (ug/L)	Notes
Lincoln Douglas	10/17/17	S - Sink	First Draw	9.18	need to flush for 60 seconds before use
Lincoln Douglas	10/17/17	S - Sink	Flush	< 2.00	need to flush for 60 seconds before use
Lincoln Douglas	10/17/17	DF - Drinking Fountain	First Draw	3.28	
Lincoln Douglas	10/17/17	DF - Drinking Fountain	Flush	3.61	
Lincoln Douglas	10/17/17	DF - Drinking Fountain	First Draw	2.55	
Lincoln Douglas	10/17/17	DF - Drinking Fountain	Flush	4.41	
Lincoln Douglas	10/17/17	DF - Drinking Fountain	First Draw	< 2.00	
Lincoln Douglas	10/17/17	DF - Drinking Fountain	Flush	< 2.00	
Lincoln Douglas	10/17/17	DF - Drinking Fountain	First Draw	< 2.00	
Lincoln Douglas	10/17/17	DF - Drinking Fountain	Flush	< 2.00	
Lincoln Douglas	10/17/17	DF - Drinking Fountain	First Draw	< 2.00	
Lincoln Douglas	10/17/17	DF - Drinking Fountain	Flush	< 2.00	
Lincoln Douglas	10/17/17	DF - Drinking Fountain	First Draw	< 2.00	
Lincoln Douglas	10/17/17	DF - Drinking Fountain	Flush	< 2.00	